

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Original Certificate

Certificate reference : RMR23 Number : RMR24

DETAILS

CLASS 1 ROCK MY RECEPTION LIMITED DATE 1-1-24



TEST EQUIPMENT DETAILS

Tested by K.Stokes **Date** 1-1-24 **Retest Date** 1-1-25

I.D NO.	Make / Model	Location	Earth Connection Ohms	Insulation Resistance	Polarity	Fuse Rating	Leakage Current	Functional Check	Pass or Fail
001	BOSE P.A SYSTEM	MOBILE	0.09	20	n/a	13AM	PASS	OK	PASS ✓
002	G4M P.A SYSTEM	MOBILE	0.09	20	n/a	13 AM	PASS	OK	PASS ✓
003	WAY- 25M EXT REEL	MOBILE	YES	20	n/a	13 AM	PASS	OK	PASS ✓
004	4 WAY 10 M EXT REEL	MOBILE	YES	20	n/a	13 AM	PASS	OK	PASS ✓
005	DJ SY. DESK/MIXER	MOBILE	YES	20	n/a	13 AM	PASS	OK	PASS ✓
007	G4M LED LIGHTS	MOBILE	YES	20	n/a	13 AM	PASS	OK	PASS ✓
008	G4M LED LIGHTS	MOBILE	YES	20	n/a	13 AM	PASS	OK	PASS ✓